



Mahabal Enviro Engineers Pvt. Ltd.

Plot No. 13/14, Opp. Patel Petrol Pump, Chinndwara Road, Koradi, Dist. Nagpur – 411 111

NOISE POLLUTION MONITORING REPORT

Name and Address of Customer	Indiabulls Realtech Ltd. (SEZ Co-Developer) Indiabulls Industrial Infrastructure Ltd. (Multiproduct SEZ) , Village – Musalgaon & Gulvanch, Tal- Sinnar, Nashik.
Date of Sampling – 27/01/2011	

Sr. No.	Location		Time	Sound Level dB (A) Fast Response	
1.	Near weigh bridge		1505	70.1	
			0205	51.5	
2.	Near Boiler Turbine Generator Area		1515	60.3	
			0215	49.2	
3.	Near Admin Building		1530	58.3	
			0230	48.2	
Noise Level Standards					
As per MPCB Limits			Permissible Exposure Period as per Factories Act.		
Area Code	Area Type	Limits in dB (A)weighted scale		Total hours of sound exposure per day	Level
		Day	Night		
A	Industrial	75	70	8	90
				6	92
				4	95

-----End-----
FOR MAHABAL ENVIRO ENGINEERS PVT LTD

Harish P. Mendhi
Technical Manager
AUTHORISED SIGNATORY

Page 1 of 1