



Mahabal Enviro Engineers Pvt. Ltd.

Plot No. 13/14, Opp. Patel Petrol Pump, Chinndwara Road, Koradi, Dist. Nagpur – 411 111

NOISE POLLUTION MONITORING REPORT

Name and Address of Customer	Indiabulls Realtech Ltd. (SEZ Co-Developer) Indiabulls Industrial Infrastructure Ltd. (Multiproduct SEZ) , Village – Musalgaon & Gulvanch, Tal- Sinnar, Nashik.
Date of Sampling –15/12/2010	

Sr. No.	Location		Time	Sound Level dB (A) Fast Response	
1.	Near weigh bridge		1635	67.6	
			0350	50.4	
2.	Near Boiler Turbine Generator Area		1620	58.7	
			0330	48.2	
3.	Near Admin Building		1600	60.3	
			0300	47.4	
Noise Level Standards					
As per MPCB Limits			Permissible Exposure Period as per Factories Act.		
Area Code	Area Type	Limits in dB (A)weighted scale		Total hours of sound exposure per day	Level
		Day	Night	Hours	dB(A)
A	Industrial	75	70	8	90
				6	92
				4	95

-----End-----

FOR MAHABAL ENVIRO ENGINEERS PVT LTD

For 

Harish P. Mendhi

Technical Manager

AUTHORISED SIGNATORY

Page 1 of 1